

Republic of the Philippines
GUIMBA WATER DISTRICT
DAILY CHLORINE DIOXIDE RESIDUAL MONITORING REPORT
APRIL 16-30, 2021

SAMPLING LOCATION	DAYS OF THE MONTH (Residual =PPM/ Time of Sampling)																REMARKS
	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31	
MATURANOC PUMPING STATION	0.34 8:54AM																1
PARTIDA 1		0.25 1:30PM															4
BACAYAO BOOSTER PUMPING STATION			0.33 10:45AM														3
BACAYAO PUMPING STATION				0.33 8:42AM													1
SAN MARCELINO					0.24 10:39AM												4
SAN AGUSTIN						0.25 10:25AM											4
MACATCATUIT							0.37 2:42PM										4
CAWAYANG BUGTONG								0.30 8:44AM									4
TRIALA									0.28 10:39AM								4
BANTUG PUMPING STATION										0.34 8:39AM							1
SAN FELIPE											0.28 10:33AM						4
SAN ANDRES PUMPING STATION												0.34 7:42AM					1
BUNOL													0.27 10:25AM				1
CATIMON														0.27 9:50AM			4
RUFINA HOMES V PUMPING STATION															0.34 12:45PM		4

DAILY SAMPLING: (1) Nearest point from every water source where full chlorination has been obtained (2) Nearest point of every distribution dead-end (3) nearest point reservoir outlet (4) Concessionaire's Tap
RESIDUAL SAMPLERS:

REVIEWED By:

CERTIFIED By:


FRANCIS E. ESQUIVEL
DIVISION MANAGER B-ENGINEERING


RAUDERICK A. RAMOS
SR. WATER MAINTENANCE MAN-A


ROMMEL G. GRAGASIN
DIVISION MANAGER B-PRODUCTION


ENGR. FELIXBERTO C. LEGARDA
GENERAL MANAGER


Republic of the Philippines
GUIMBA WATER DISTRICT
DAILY CHLORINE DIOXIDE RESIDUAL MONITORING REPORT
APRIL 1-15, 2021

SAMPLING LOCATION	DAYS OF THE MONTH (Residual =PPM/ Time of Sampling)															REMARKS
	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	
MANGGANG MARIKIT	0.29 10:31AM															4
STA. VERONICA PUMPING STATION		0.34 7:33AM														1
LENNEC			0.27 11:27AM													4
SAN BERNARDINO				0.27 10:31AM												4
SAN ROQUE PUMPING STATION					0.34 8:55AM											1
MANACSAC						0.27 10:29AM										4
NAGLABRAHAN							0.23 10:48AM									4
TAMPAC 2-3 PUMPING STATION								0.33 8:29AM								1
YUSON									0.22 9:26AM							4
GUISET										0.28 1:30PM						4
NAGPANDAYAN											0.27 9:50AM					4
SAN RAFAEL PUMPING STATION												0.32 10:30AM				1
STA.ANA													0.28 11:31AM			4
LAMORITO														0.23 8:45AM		4
BALINGOG WEST															0.28 9:31AM	4

DAILY SAMPLING: (1) Nearest point from every water source where full chlorination has been obtained (2) Nearest point of every distribution dead-end (3) nearest point reservoir outlet (4) Concessionaire's Tap
RESIDUAL SAMPLERS:

REVIEWED By:

CERTIFIED By:


FRANCIS E. ESQUIVEL
DIVISION MANAGER B-ENGINEERING


RAUDERICK A. RAMOS
SR. WATER MAINTENANCE MAN-A


ROMMEL G. GRAGASIN
DIVISION MANAGER B-PRODUCTION


ENGR. FELIXBERTO C. LEGARDA
GENERAL MANAGER