

Republic of the Philippines  
GUIMBA WATER DISTRICT  
DAILY CHLORINE DIOXIDE RESIDUAL MONITORING REPORT  
JANUARY 1-15, 2021

SAMPLING LOCATION	DAYS OF THE MONTH (Residual =PPM/ Time of Sampling)															REMARKS
	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	
MANGGANG MARIKIT	0.27 5:08PM															4
STA. VERONICA PUMPING STATION		0.34 8:34AM														1
STA. LUCIA			0.28 12:15PM													4
SAN BERNARDINO				0.27 9:58AM												4
SAN ROQUE PUMPING STATION					0.32 8:29AM											1
BALINGOG EAST						0.24 10:45AM										4
AYOS LOMBOY							0.28 3:55PM									4
TAMPAC 2-3 PUMPING STATION								0.33 9:01AM								1
ST. JOHN									0.28 10:16AM							4
STA. CRUZ										0.27 9:29AM						4
BALINGOG WEST											0.27 10:29AM					4
SAN RAFAEL PUMPING STATION												0.32 9:28AM				1
SAN AGUSTIN													0.25 3:55PM			4
LENNEC														0.28 9:40AM		4
CAMIING															0.27 10:40AM	4

DAILY SAMPLING: (1) Nearest point from every water source where full chlorination has been obtained (2) Nearest point of every distribution dead-end (3) nearest point reservoir outlet (4) Concessionaire's Tap

RESIDUAL SAMPLERS:

REVIEWED By:

CERTIFIED By:

  
FRANCIS E. ESQUIVEL  
DIVISION MANAGER B-ENGINEERING

  
RAUDERICK A. RAMOS  
SR. WATER MAINTENANCE MAN-A

  
ROMMEL G. GRAGASIN  
DIVISION MANAGER B-PRODUCTION

  
ENGR. FELIXBERTO C. LEGARDA  
GENERAL MANAGER

Republic of the Philippines  
GUIMBA WATER DISTRICT  
DAILY CHLORINE DIOXIDE RESIDUAL MONITORING REPORT  
JANUARY 16-31, 2021


SAMPLING LOCATION	DAYS OF THE MONTH ( Residual =PPM/ Time of Sampling)																REMARKS
	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31	
MATURANOC PUMPING STATION	0.32 8:42AM																1
CULONG		0.27 12:01PM															4
BACAYAO PUMPING STATION			0.33 8:27AM														1
SAN FELIPE				0.24 10:11AM													4
BACAYAO BOOSTER PUMPING STATION					0.20 9:19AM												3
NAGPANDAYAN						0.26 10:19PM											4
YUSON							0.22 10:19AM										4
RUFINA HOMES V PUMPING STATION								0.35 10:28PM									4
NAGLABRAHAN									0.22 12:00PM								4
AGCANO										0.25 10:02AM							4
CAVITE											0.28 9:31AM						4
SAN ANDRES PUMPING STATION												0.32 7:18AM					1
SINULATAN													0.24 10:21AM				4
BANTUG PUMPING STATION														0.33 8:25AM			1
SUBOL															0.28 8:53AM		4
CAWAYANG BUGTONG																0.27 9:23AM	4

DAILY SAMPLING: (1) Nearest point from every water source where full chlorination has been obtained (2) Nearest point of every distribution dead-end (3) nearest point reservoir outlet (4) Concessionaire's Tap  
RESIDUAL SAMPLERS:

REVIEWED By:

CERTIFIED By:

  
FRANCIS E. ESQUIVEL  
DIVISION MANAGER B-ENGINEERING

  
RAUDERICK A. RAMOS  
SR. WATER MAINTENANCE MAN-A

  
ROMMEL G. GRAGASIN  
DIVISION MANAGER B-PRODUCTION

  
ENGR. FELIXBERTO C. LEGARDA  
GENERAL MANAGER