

Republic of the Philippines
GUIMBA WATER DISTRICT
DAILY CHLORINE DIOXIDE RESIDUAL MONITORING REPO
JULY 1-15, 2020


SAMPLING LOCATION	DAYS OF THE MONTH (Residual =PPM/ Time of Sampling)															REMARKS
	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	
BANITAN	0.26 8:12AM															4
STA. VERONICA PUMPING STATION		0.33 7:00AM														1
CAMIING			0.23 9:17AM													4
MANGANG MARIKIT				0.28 2:31PM												4
SAN ROQUE PUMPING STATION					0.32 8:52AM											1
CAWAYANG BUGTONG						0.27 3:38PM										4
GUISET							0.22 2:26PM									4
TAMPAC 2-3 PUMPING STATION								0.31 8:33AM								1
PARTIDA 1									0.22 3:14PM							4
CARDINAL										0.26 2:40PM						4
BALINGOG EAST											0.23 10:00AM					4
SAN RAFAEL PUMPING STATION												0.32 8:35AM				1
YUSON													0.25 2:49PM			4
CATIMON														0.23 3:14PM		4
SAN MARCELINO															0.22 10:57AM	4

DAILY SAMPLING: (1) Nearest point from every water source where full chlorination has been obtained (2) Nearest point of every distribution dead-end (3) nearest point reservoir outlet (4) Concessionaire's Tap
RESIDUAL SAMPLERS:

REVIEWED By:

CERTIFIED By:


FRANCIS E. ESQUIVEL
DIVISION MANAGER B-ENGINEERING


RAUDERICK A. RAMOS
SR. WATER MAINTENANCE MAN-A


ROMMEL G. GRAGASIN
DIVISION MANAGER B-PRODUCTION


ENGR. FELIXBERTO C. LEGARDA
GENERAL MANAGER

Republic of the Philippines
GUIMBA WATER DISTRICT
DAILY CHLORINE DIOXIDE RESIDUAL MONITORING REPORT
JULY 16-31, 2020

SAMPLING LOCATION	DAYS OF THE MONTH (Residual =PPM/ Time of Sampling)																REMARKS
	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31	
MATURANOC PUMPING STATION	0.31 7:31AM																1
NAGPANDAYAN		0.26 10:01AM															4
LENNEC			0.25 8:28AM														4
NAGLABRAHAN				0.23 2:55PM													4
BACAYAO BOOSTER PUMPING STATION					0.29 8:00M												3
BACAYAO PUMPING STATION						0.33 2:21PM											1
SINULATAN							0.26 9:29AM										4
PACAC								0.28 8:50AM									4
CARDINAL									0.24 10:29AM								4
BANITAN										0.27 9:15AM							4
NAGPANDAYAN											0.24 10:15AM						4
SAN MIGUEL												0.27 9:51AM					4
NAGLABRAHAN													0.23 3:45PM				4
SAN FELIPE, LENNEC														0.24 2:06PM			4
SAN ANDRES PUMPING STATION															0.26 5:00PM		1
BANTUG PUMPING STATION																0.30 2:17PM	1

DAILY SAMPLING: (1) Nearest point from every water source where full chlorination has been obtained (2) Nearest point of every distribution dead-end (3) nearest point reservoir outlet (4) Concessionaire's Tap
RESIDUAL SAMPLERS:

REVIEWED By:

CERTIFIED By:


FRANCIS E. ESQUIVEL
DIVISION MANAGER B-ENGINEERING


RAUDERICK A. RAMOS
SR. WATER MAINTENANCE MAN-A


ROMMEL G. GRAGASIN
DIVISION MANAGER B-PRODUCTION


ENGR. FELIXBERTO C. LEGARDA
GENERAL MANAGER