


Republic of the Philippines
GUIMBA WATER DISTRICT
DAILY CHLORINE DIOXIDE RESIDUAL MONITORING REPORT
JUNE 16-30, 2020

SAMPLING LOCATION	DAYS OF THE MONTH (Residual =PPM/ Time of Sampling)																REMARKS
	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31	
CATIMON	0.26 2:13PM																4
SINULATAN		0.26 9:06AM															4
ESCAÑO			0.24 9:05AM														4
SAN ROQUE PUMPING STATION				0.35 1:30PM													1
BALINGOG EAST					0.29 2:18PM												4
MATURANOC PUMPING STATION						0.36 8:15AM											1
CAWAYANG BUGTONG							0.31 1:47PM										4
TAMPAC 1								0.32 9:15AM									4
PARTIDA 1									0.30 2:14PM								4
CABALLERO										0.27 9:15AM							4
BANTUG PUMPING STATION											0.38 7:30AM						1
BALBALINO												0.33 8:45AM					4
LENNEC													0.31 2:15PM				4
NAGPANDAYAN														0.29 2:38PM			4
SAN RAFAEL PUMPING STATION															0.36 7:30AM		1

DAILY SAMPLING: (1) Nearest point from every water source where full chlorination has been obtained (2) Nearest point of every distribution dead-end (3) nearest point reservoir outlet (4) Concessionaire's Tap
RESIDUAL SAMPLERS:


REVIEWED By:

CERTIFIED By:


FRANCIS E. ESQUIVEL
DIVISION MANAGER B-ENGINEERING


RAUDERICK A. RAMOS
SR. WATER MAINTENANCE MAN-A


ROMMEL G. GRAGASIN
DIVISION MANAGER B-PRODUCTION


ENGR. FELIXBERTO C. LEGARDA
GENERAL MANAGER

Republic of the Philippines
GUIMBA WATER DISTRICT
DAILY CHLORINE DIOXIDE RESIDUAL MONITORING REPO
JUNE 1-15, 2020

SAMPLING LOCATION	DAYS OF THE MONTH (Residual =PPM/ Time of Sampling)															REMARKS
	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	
BALINGOG WEST	0.28 10:10AM															4
CABARUAN		0.29 10:10AM														4
BACAYAO PUMPING STATION			0.35 1:00PM													1
SAN BERNARDINO				0.28 10:36AM												4
STA. VERONICA PUMPING STATION					0.38 7:30AM											1
BALINGOG EAST						0.30 9:45AM										4
TRIALA							0.28 2:38PM									4
TAMPAC 2-3 PUMPING STATION								0.37 7:15AM								1
SAN ROQUE PUMPING STATION									0.35 8:36AM							4
CATIMON										0.30 10:13AM						4
BUNOL											0.25 2:38PM					4
BACAYAO BOOSTER PUMPING STATION												0.34 7:30AM				3
SAN ANDRES PUMPING STATION													0.37 9:15AM			1
YUSON														0.28 2:15PM		4
BANITAN															0.30 10:00AM	4

DAILY SAMPLING: (1) Nearest point from every water source where full chlorination has been obtained (2) Nearest point of every distribution dead-end (3) nearest point reservoir outlet (4) Concessionaire's Tap
RESIDUAL SAMPLERS:

REVIEWED By:

CERTIFIED By:


FRANCIS E. ESQUIVEL
DIVISION MANAGER B-ENGINEERING


RAUDERICK A. RAMOS
SR. WATER MAINTENANCE MAN-A


ROMMEL G. GRAGASIN
DIVISION MANAGER B-PRODUCTION


ENGR. FELIXBERTO C. LEGARDA
GENERAL MANAGER