

Republic of the Philippines
GUIMBA WATER DISTRICT
DAILY CHLORINE DIOXIDE RESIDUAL MONITORING REPO
MARCH 1-15, 2020

SAMPLING LOCATION	DAYS OF THE MONTH (Residual =PPM/ Time of Sampling)															REMARKS
	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	
BACAYAO BOOSTER PUMPING STATION	0.32 10:31AM															3
SAN ANDRES PUMPING STATION		0.30 8:58AM														4
CARDINAL			0.26 2:15PM													4
AGCANO				0.27 1:36PM												4
BANTUG PUMPING STATION					0.32 11:09AM											1
SUBOL						0.25 11:17AM										4
BALINGOG EAST							0.28 2:36AM									4
CAMIING TABING ILOG								0.29 0:29AM								4
MATURANOC PUMPING STATION									0.31 9:01AM							1
SAN BERNARDINO										0.30 10:11AM						4
CABALLERO											0.27 11:15AM					4
STA CRUZ												0.29 11:15AM				4
STA. VERONICA PUMPING STATION													0.32 9:11AM			1
SINULATAN														0.28 8:26AM		4
FAIGAL															0.27 9:32AM	4

DAILY SAMPLING: (1) Nearest point from every water source where full chlorination has been obtained (2) Nearest point of every distribution dead-end (3) nearest point reservoir outlet (4) Concessionaire's Tap
RESIDUAL SAMPLERS:

REVIEWED By:

CERTIFIED By:


FRANCIS E. ESQUIVEL
DIVISION MANAGER B-ENGINEERING


CARLUEN M. GUIANG
DRIVER


ROMMEL G. GRAGASIN
DIVISION MANAGER B-PRODUCTION


ENGR. FELIXBERTO C. LEGARDA
GENERAL MANAGER

Republic of the Philippines
GUIMBA WATER DISTRICT
DAILY CHLORINE DIOXIDE RESIDUAL MONITORING REPORT
MARCH 16-31, 2020

SAMPLING LOCATION	DAYS OF THE MONTH (Residual =PPM/ Time of Sampling)																REMARKS
	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31	
TAMPAC 2-3 PUMPING STATION	0.33 1:09PM																1
NARVACAN 1		0.33 1:06PM															4
CASONGSONG			0.27 10:31AM														4
PACAC				0.29 10:51AM													4
SAN RAFAEL PUMPING STATION					0.30 8:59AM												1
CAVITE						0.27 8:19AM											4
SARANAY							0.29 8:30AM										4
BALBALINO								0.27 10:01AM									4
BACAYAO PUMPING STATION									0.33 11:45AM								1
PARTIDA 1										0.26 9:33AM							4
CALEM											0.29 8:07AM						4
MACAMIAS												0.29 8:45AM					4
SAN ROQUE PUMPING STATION													0.33 1:46PM				1
ESCAÑO														0.29 10:21AM			4
YUSON															0.30 9:18AM		4
BAGONG BARYO																0.30 8:53AM	4

DAILY SAMPLING: (1) Nearest point from every water source where full chlorination has been obtained (2) Nearest point of every distribution dead-end (3) nearest point reservoir outlet (4) Concessionaire's Tap
RESIDUAL SAMPLERS:


FRANCIS E. ESQUIVEL
DIVISION MANAGER B-ENGINEERING


CARLUEN M. GUIANG
DRIVER

REVIEWED By:


ROMMEL G. GRAGASIN
DIVISION MANAGER B-PRODUCTION

CERTIFIED By:


ENGR. FELIXBERTO C. LEGARDA
GENERAL MANAGER