

Republic of the Philippines
GUIMBA WATER DISTRICT
DAILY CHLORINE DIOXIDE RESIDUAL MONITORING REPO
MAY 1-15, 2020


SAMPLING LOCATION	DAYS OF THE MONTH (Residual =PPM/ Time of Sampling)															REMARKS
	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	
MANGANG MARIKIT	0.29 10:56AM															4
SAN ANDRES PUMPING STATION		0.28 5:10PM														1
BAGONG BARIO			0.30 11:12AM													4
STA. VERONICA PUMPING STATION				0.32 10:43AM												1
BACAYAO BOOSTER PUMPING STATION					0.31 11:15AM											3
LAMORITO						0.30 11:35AM										4
MAYBUBON							0.30 10:58AM									4
BUNOL								0.29 10:27AM								4
TRIALA									0.31 9:02AM							4
CONSUELO										0.31 10:49AM						4
BULAKID											0.31 11:15AM					4
TAMPAC 2-3 PUMPING STATION												0.31 9:55AM				1
BACAYAO PUMPING STATION													0.32 9:59AM			1
PACAC														0.30 11:29AM		4
SAN MARCELINO															0.30 11:48AM	4

DAILY SAMPLING: (1) Nearest point from every water source where full chlorination has been obtained (2) Nearest point of every distribution dead-end (3) nearest point reservoir outlet (4) Concessionaire's Tap
RESIDUAL SAMPLERS:

REVIEWED By:

CERTIFIED By:


FRANCIS E. ESQUIVEL
DIVISION MANAGER B-ENGINEERING


CARLUEN M. GUIANG / RAUDERICK A. RAMOS
DRIVER/SR. WATER MAINTENANCE MAN-A


ROMMEL G. GRAGASIN
DIVISION MANAGER B-PRODUCTION



ENGR. FELIXBERTO C. LEGARDA
GENERAL MANAGER

Republic of the Philippines
GUIMBA WATER DISTRICT
DAILY CHLORINE DIOXIDE RESIDUAL MONITORING REPORT
MAY 16-31, 2020

SAMPLING LOCATION	DAYS OF THE MONTH (Residual =PPM/ Time of Sampling)																REMARKS
	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31	
NARVACAN 2	0.30 10:09AM																4
SAN RAFAEL		0.31 10:30AM															4
SAN ROQUE PUMPING STATION			0.29 10:18AM														1
CAWAYANG BUGTONG				0.29 1:29PM													4
STA. CRUZ					0.30 2:15PM												4
AGCANO						0.29 10:16AM											4
BANTUG PUMPING STATION							0.34 8:12AM										1
MANACSAC								0.31 1:59PM									4
MATURANOC PUMPING STATION									0.31 11:09AM								1
SUBOL										0.29 10:01AM							4
PAONG INCHICK											0.30 1:15PM						4
BALINGOG EAST												0.30 10:09AM					4
SAN RAFAEL PUMPING STATION													0.31 9:01AM				1
PARTIDA 1														0.28 11:08AM			4
MACAMIAS															0.30 11:05AM		4
MACATCATWIT																0.30 10:49AM	4

DAILY SAMPLING: (1) Nearest point from every water source where full chlorination has been obtained (2) Nearest point of every distribution dead-end (3) nearest point reservoir outlet (4) Concessionaire's Tap
RESIDUAL SAMPLERS:


FRANCIS E. ESQUIVEL
DIVISION MANAGER B-ENGINEERING


CARLUEN M. GUIANG/RAUDERICK A. RAMOS
DRIVER/SR. WATER MAINTENANCE MAN-A

REVIEWED By:


ROMMEL G. GRAGASIN
DIVISION MANAGER B-PRODUCTION

CERTIFIED By:


ENGR. FELIXBERTO C. LEGARDA
GENERAL MANAGER