

Republic of the Philippines  
GUIMBA WATER DISTRICT  
DAILY CHLORINE DIOXIDE RESIDUAL MONITORING REPORT  
OCTOBER 16-31, 2020


SAMPLING LOCATION	DAYS OF THE MONTH ( Residual =PPM/ Time of Sampling)																REMARKS
	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31	
MATURANOC PUMPING STATION	0.33 1:38AM																1
BACAYAO BOOSTER PUMPING STATION		0.32 9:35AM															3
BALBALINO			0.27 8:13AM														4
SINULATAN				0.23 10:46AM													4
BACAYAO PUMPING STATION					0.30 8:15AM												1
BANITAN						0.28 1:25PM											4
PACAC							0.27 10:19AM										4
CATIMON								0.25 8:53AM									4
BAGONG BARRIO									0.23 2:03PM								4
SAN MARCELINO										0.25 10:10AM							4
SAN MIGUEL											0.25 10:47AM						4
SAN ANDRES PUMPING STATION												0.30 10:00AM					1
CAVITE													0.28 1:32PM				4
BANTUG PUMPING STATION														0.31 7:48AM			1
FAIGAL															0.22 1:38PM		4
MANGANG MARIKIT																0.32 1:49PM	4

DAILY SAMPLING: (1) Nearest point from every water source where full chlorination has been obtained (2) Nearest point of every distribution dead-end (3) nearest point reservoir outlet (4) Concessionaire's Tap  
RESIDUAL SAMPLERS:

REVIEWED By:

CERTIFIED By:

  
FRANCIS E. ESQUIVEL  
DIVISION MANAGER B-ENGINEERING

  
RAUDERICK A. RAMOS  
SR. WATER MAINTENANCE MAN-A

  
ROMMEL G. GRAGASIN  
DIVISION MANAGER B-PRODUCTION

  
ENGR. FELIXBERTO C. LEGARDA  
GENERAL MANAGER

Republic of the Philippines  
GUIMBA WATER DISTRICT  
DAILY CHLORINE DIOXIDE RESIDUAL MONITORING REPO  
OCTOBER 1-15, 2020

SAMPLING LOCATION	DAYS OF THE MONTH (Residual =PPM/ Time of Sampling)															REMARKS
	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	
PARTIDA 1	0.22 9:59AM															4
STA. VERONICA PUMPING STATION		0.32 1:00PM														1
BALINGOG EAST			0.25 2:17PM													4
BUNOL				0.23 1:37PM												4
SAN ROQUE PUMPING STATION					0.32 7:13AM											1
BALBALINO						0.24 10:25AM										4
CAWAYANG BUGTONG							0.26 2:02PM									4
TAMPAC 2-3 PUMPING STATION								0.34 8:28AM								1
TRIALA									0.28 2:02PM							4
STA. CRUZ										0.27 2:33PM						4
BALINGOG WEST											0.23 2:42PM					4
SAN RAFAEL PUMPING STATION												0.34 9:48AM				1
CAMIING													0.25 7:28AM			4
ESCAÑO														0.22 9:39AM		4
MANACSAC															0.27 2:14PM	4

DAILY SAMPLING: (1) Nearest point from every water source where full chlorination has been obtained (2) Nearest point of every distribution dead-end (3) nearest point reservoir outlet (4) Concessionaire's Tap  
RESIDUAL SAMPLERS:

REVIEWED By:

CERTIFIED By:

  
FRANCIS E. ESQUIVEL  
DIVISION MANAGER B-ENGINEERING

  
RAUDERICK A. RAMOS  
SR. WATER MAINTENANCE MAN-A

  
ROMMEL G. GIAGASIN  
DIVISION MANAGER B-PRODUCTION

  
ENGR. FELIXBERTO C. LEGARDA  
GENERAL MANAGER