

WATER MICROBIOLOGY ANALYSIS REPORT

Client :	GUIMBA WATER DISTRICT	WMAR No :	21-0725Y
Owner/Manager :	ENGR. FELIXBERTO C. LEGARDA	Date Received :	11/02/2021
Address	DANZALAN ST., CORNER FAIGAL ST., GUIMBA, NUEVA ECIJA	Date Analyzed :	11/02/2021
		Date Completed :	11/04/2021


Physical Characteristics : **Sample is clear, with no foreign matter**


Sample Name	Date and Time of Sampling	Heterotrophic Plate Count (Est. CFU/mL)	Total Coliform	Thermotolerant Coliform / <i>E. coli</i>	Remarks
			(MPN/100mL)		
Rufina Homes 5 Pump Station	November 02, 2021 08:28 AM	97	<1.1	<1.1	PASSED
PNSDW Limits AO 2017-0010		<500	<1.1	<1.1	

Est. CFU/mL = Estimated Colony Forming Units per milliliter

MPN/100mL = Most Probable Number per 100 milliliters

- Note :
- Test method used:
 - Pour Plate Method for the determination of Heterotrophic Plate Count
 - Multiple Tube Fermentation Technique for the determination of Total Coliform and Thermotolerant Coliform/E.coli
 - References:
 - Philippine National Standards for Drinking Water, 2017
 - Standard Methods for the Examination of Water and Wastewater, 22nd Edition, 2012, APHA, AWWA, WEF
 - Result of examination **specifically** relates to samples as received


Veronica A. Presentacion, RMicro
Analyst, PAM No. 18-00303


Susana P. Quiaoit, MD, FPSP
Head of the Laboratory, PRC No. 64242

Not Valid Without Dry Seal

WATER MICROBIOLOGY ANALYSIS REPORT

Client :	GUIMBA WATER DISTRICT	WMAR No :	21-0725X
Owner/Manager :	ENGR. FELIXBERTO C. LEGARDA	Date Received :	11/02/2021
Address	DANZALAN ST., CORNER FAIGAL ST., GUIMBA, NUEVA ECIJA	Date Analyzed :	11/02/2021
		Date Completed :	11/04/2021

Physical Characteristics : **Sample is clear, with no foreign matter**


Sample Name	Date and Time of Sampling	Heterotrophic Plate Count (Est. CFU/mL)	Total Coliform	Thermotolerant Coliform / <i>E. coli</i>	Remarks
			(MPN/100mL)		
San Marcelino	November 02, 2021 08:14 AM	77	<1,1	<1,1	PASSED
PNSDW Limits AO 2017-0010		<500	<1,1	<1,1	

Est. CFU/mL = Estimated Colony Forming Units per milliliter

MPN/100mL = Most Probable Number per 100 milliliters

- Note :
- Test method used:
 - Pour Plate Method for the determination of Heterotrophic Plate Count
 - Multiple Tube Fermentation Technique for the determination of Total Coliform and Thermotolerant Coliform/*E. coli*
 - References:
 - Philippine National Standards for Drinking Water, 2017
 - Standard Methods for the Examination of Water and Wastewater, 22nd Edition, 2012, APHA, AWWA, WEF
 - Result of examination **specifically** relates to samples as received


Veronica A. Presentacion, RMicro
Analyst, PAM No. 18-00303


Susana P. Quiaoit, MD, FPSP
Head of the Laboratory, PRC No. 64242

Not Valid Without Dry Seal

WATER MICROBIOLOGY ANALYSIS REPORT

Client :	GUIMBA WATER DISTRICT	WMAR No :	21-0725W
Owner/Manager :	ENGR. FELIXBERTO C. LEGARDA	Date Received :	11/02/2021
Address	DANZALAN ST., CORNER FAIGAL ST., GUIMBA, NUEVA ECIJA	Date Analyzed :	11/02/2021
		Date Completed :	11/04/2021

Physical Characteristics : **Sample is clear, with no foreign matter**


Sample Name	Date and Time of Sampling	Heterotrophic Plate Count (Est. CFU/mL)	Total Coliform	Thermotolerant Coliform / <i>E. coli</i>	Remarks
			(MPN/100mL)		
Guiset	November 02, 2021 08:00 AM	1	<1.1	<1.1	PASSED
PNSDW Limits AO 2017-0010		<500	<1.1	<1.1	

Est. CFU/mL = Estimated Colony Forming Units per milliliter

MPN/100mL = Most Probable Number per 100 milliliters

- Note :
- Test method used:
 - Pour Plate Method for the determination of Heterotrophic Plate Count
 - Multiple Tube Fermentation Technique for the determination of Total Coliform and Thermotolerant Coliform/E.coli
 - References:
 - Philippine National Standards for Drinking Water, 2017
 - Standard Methods for the Examination of Water and Wastewater, 22nd Edition, 2012, APHA, AWWA, WEF
 - Result of examination **specifically** relates to samples as received


Veronica A. Presentation, RMicro
Analyst, PAM No. 18-00303


Susana P. Quiaoit, MD, FPSP
Head of the Laboratory, PRC No. 64242

WATER MICROBIOLOGY ANALYSIS REPORT

Client :	GUIMBA WATER DISTRICT	WMAR No :	21-0725V
Owner/Manager :	ENGR. FELIXBERTO C. LEGARDA	Date Received :	11/02/2021
Address	DANZALAN ST., CORNER FAIGAL ST., GUIMBA, NUEVA ECIJA	Date Analyzed :	11/02/2021
		Date Completed :	11/04/2021

Physical Characteristics : **Sample is clear, with no foreign matter**


Sample Name	Date and Time of Sampling	Heterotrophic Plate Count (Est. CFU/mL)	Total Coliform	Thermotolerant Coliform / <i>E. coli</i>	Remarks
			(MPN/100mL)		
San Andres Pump Station	November 02, 2021 07:52 AM	<1	<1.1	<1.1	PASSED
PNSDW Limits AO 2017-0010		<500	<1.1	<1.1	

Est. CFU/mL = Estimated Colony Forming Units per milliliter

MPN/100mL = Most Probable Number per 100 milliliters

- Note :**
- Test method used:
 - Pour Plate Method for the determination of Heterotrophic Plate Count
 - Multiple Tube Fermentation Technique for the determination of Total Coliform and Thermotolerant Coliform/E.coli
 - References:
 - Philippine National Standards for Drinking Water, 2017
 - Standard Methods for the Examination of Water and Wastewater, 22nd Edition, 2012, APHA, AWWA, WEF
 - Result of examination **specifically** relates to samples as received


Veronica A. Presentacion, RMicro
Analyst, PAM No. 18-00303


Susana P. Quiaoit, MD, FPSP
Head of the Laboratory, PRC No. 64242

Not Valid Without Dry Seal

WATER MICROBIOLOGY ANALYSIS REPORT

Client :	GUIMBA WATER DISTRICT	WMAR No :	21-0725U
Owner/Manager :	ENGR. FELIXBERTO C. LEGARDA	Date Received :	11/02/2021
Address	DANZALAN ST., CORNER FAIGAL ST., GUIMBA, NUEVA ECIJA	Date Analyzed :	11/02/2021
		Date Completed :	11/04/2021


Physical Characteristics : **Sample is clear, with no foreign matter**


Sample Name	Date and Time of Sampling	Heterotrophic Plate Count (Est. CFU/mL)	Total Coliform	Thermotolerant Coliform / <i>E. coli</i>	Remarks
			(MPN/100mL)		
San Bernardino	November 02, 2021 07:30 AM	1	<1.1	<1.1	PASSED
PNSDW Limits AO 2017-0010		<500	<1.1	<1.1	

Est. CFU/mL = Estimated Colony Forming Units per milliliter

MPN/100mL = Most Probable Number per 100 milliliters

- Note :**
- Test method used:
 - Pour Plate Method for the determination of Heterotrophic Plate Count
 - Multiple Tube Fermentation Technique for the determination of Total Coliform and Thermotolerant Coliform/E.coli
 - References:
 - Philippine National Standards for Drinking Water, 2017
 - Standard Methods for the Examination of Water and Wastewater, 22nd Edition, 2012, APHA, AWWA, WEF
 - Result of examination **specifically** relates to samples as received


Veronica A. Presentacion, RMicro
Analyst, PAM No. 18-00303


Susana P. Quiaoit, MD, FPSP
Head of the Laboratory, PRC No. 64242

Not Valid Without Dry Seal

WATER MICROBIOLOGY ANALYSIS REPORT

Client :	GUIMBA WATER DISTRICT	WMAR No :	21-0725T
Owner/Manager :	ENGR. FELIXBERTO C. LEGARDA	Date Received :	11/02/2021
Address	DANZALAN ST., CORNER FAIGAL ST., GUIMBA, NUEVA ECIJA	Date Analyzed :	11/02/2021
		Date Completed :	11/04/2021

Physical Characteristics : **Sample is clear, with no foreign matter**

Sample Name	Date and Time of Sampling	Heterotrophic Plate Count (Est. CFU/mL)	Total Coliform	Thermotolerant Coliform / <i>E. coli</i>	Remarks
			(MPN/100mL)		
Sta. Cruz	November 02, 2021 07:22 AM	97	<1.1	<1.1	PASSED
PNSDW Limits AO 2017-0010		<500	<1.1	<1.1	


Est. CFU/mL = Estimated Colony Forming Units per milliliter

MPN/100mL = Most Probable Number per 100 milliliters

- Note :
- Test method used:
 - Pour Plate Method for the determination of Heterotrophic Plate Count
 - Multiple Tube Fermentation Technique for the determination of Total Coliform and Thermotolerant Coliform/*E. coli*
 - References:
 - Philippine National Standards for Drinking Water, 2017
 - Standard Methods for the Examination of Water and Wastewater, 22nd Edition, 2012, APHA, AWWA, WEF
 - Result of examination **specifically** relates to samples as received



Veronica A. Presentacion, RMicro
Analyst, PAM No. 18-00303



Susana P. Quiaoit, MD, FPSP
Head of the Laboratory, PRC No. 64242

Not Valid Without Dry Seal

WATER MICROBIOLOGY ANALYSIS REPORT

Client :	GUIMBA WATER DISTRICT	WMAR No :	21-0725S
Owner/Manager :	ENGR. FELIXBERTO C. LEGARDA	Date Received :	11/02/2021
Address	DANZALAN ST., CORNER FAIGAL ST., GUIMBA, NUEVA ECIJA	Date Analyzed :	11/02/2021
		Date Completed :	11/04/2021

Physical Characteristics : **Sample is clear, with no foreign matter**


Sample Name	Date and Time of Sampling	Heterotrophic Plate Count (Est. CFU/mL)	Total Coliform	Thermotolerant Coliform / <i>E. coli</i>	Remarks
			(MPN/100mL)		
Tampac 2/3 Pump Station	November 02, 2021 07:14 AM	170	<1.1	<1.1	PASSED
PNSDW Limits AO 2017-0010		<500	<1.1	<1.1	

Est. CFU/mL = Estimated Colony Forming Units per milliliter

MPN/100mL = Most Probable Number per 100 milliliters

- Note :
- Test method used:
 - Pour Plate Method for the determination of Heterotrophic Plate Count
 - Multiple Tube Fermentation Technique for the determination of Total Coliform and Thermotolerant Coliform/E.coli
 - References:
 - Philippine National Standards for Drinking Water, 2017
 - Standard Methods for the Examination of Water and Wastewater, 22nd Edition, 2012, APHA, AWWA, WEF
 - Result of examination **specifically** relates to samples as received


Veronica A. Presentation, RMicro
Analyst, PAM No. 18-00303


Susana P. Quilait, MD, FPSP
Head of the Laboratory, PRC No. 64242

Not Valid Without Dry Seal

WATER MICROBIOLOGY ANALYSIS REPORT

Client :	GUIMBA WATER DISTRICT	WMAR No :	21-0725R
Owner/Manager :	ENGR. FELIXBERTO C. LEGARDA	Date Received :	11/02/2021
Address	DANZALAN ST., CORNER FAIGAL ST., GUIMBA, NUEVA ECIJA	Date Analyzed :	11/02/2021
		Date Completed :	11/04/2021

Physical Characteristics : **Sample is clear, with no foreign matter**


Sample Name	Date and Time of Sampling	Heterotrophic Plate Count (Est. CFU/mL)	Total Coliform	Thermotolerant Coliform / <i>E. coli</i>	Remarks
			(MPN/100mL)		
Balingog West	November 02, 2021 06:55 AM	<1	<1.1	<1.1	PASSED
PNSDW Limits AO 2017-0010		<500	<1.1	<1.1	

Est. CFU/mL = Estimated Colony Forming Units per milliliter

MPN/100mL = Most Probable Number per 100 milliliters

- Note :**
- Test method used:
 - Pour Plate Method for the determination of Heterotrophic Plate Count
 - Multiple Tube Fermentation Technique for the determination of Total Coliform and Thermotolerant Coliform/E.coli
 - References:
 - Philippine National Standards for Drinking Water, 2017
 - Standard Methods for the Examination of Water and Wastewater, 22nd Edition, 2012, APHA, AWWA, WEF
 - Result of examination **specifically** relates to samples as received


Veronica A. Presentacion, RMicro
Analyst, PAM No. 18-00303


Susana P. Quilaol, MD, FPSP
Head of the Laboratory, PRC No. 64242

Not Valid Without Dry Seal

WATER MICROBIOLOGY ANALYSIS REPORT

Client :	GUIMBA WATER DISTRICT	WMAR No :	21-0725Q
Owner/Manager :	ENGR. FELIXBERTO C. LEGARDA	Date Received :	11/02/2021
Address	DANZALAN ST., CORNER FAIGAL ST., GUIMBA, NUEVA ECIJA	Date Analyzed :	11/02/2021
		Date Completed :	11/04/2021


Physical Characteristics : **Sample is clear, with no foreign matter**

Sample Name	Date and Time of Sampling	Heterotrophic Plate Count (Est. CFU/mL)	Total Coliform	Thermotolerant Coliform / <i>E. coli</i>	Remarks
			(MPN/100mL)		
Banitan	November 02, 2021 06:47 AM	1	<1.1	<1.1	PASSED
PNSDW Limits AO 2017-0010		<500	<1.1	<1.1	


Est. CFU/mL = Estimated Colony Forming Units per milliliter

MPN/100mL = Most Probable Number per 100 milliliters

- Note :**
- Test method used:
 - Pour Plate Method for the determination of Heterotrophic Plate Count
 - Multiple Tube Fermentation Technique for the determination of Total Coliform and Thermotolerant Coliform/E.coli
 - References:
 - Philippine National Standards for Drinking Water, 2017
 - Standard Methods for the Examination of Water and Wastewater, 22nd Edition, 2012, APHA, AWWA, WEF
 - Result of examination **specifically** relates to samples as received



Veronica A. Presentacion, RMicro
Analyst, PAM No. 18-00303



Susana P. Quiaoit, MD, FPSP
Head of the Laboratory, PRC No. 64242

Not Valid Without Dry Seal

WATER MICROBIOLOGY ANALYSIS REPORT

Client :	GUIMBA WATER DISTRICT	WMAR No :	21-0725P
Owner/Manager :	ENGR. FELIXBERTO C. LEGARDA	Date Received :	11/02/2021
Address	DANZALAN ST., CORNER FAIGAL ST., GUIMBA, NUEVA ECIJA	Date Analyzed :	11/02/2021
		Date Completed :	11/04/2021


Physical Characteristics : **Sample is clear, with no foreign matter**


Sample Name	Date and Time of Sampling	Heterotrophic Plate Count (Est. CFU/mL)	Total Coliform	Thermotolerant Coliform / <i>E. coli</i>	Remarks
			(MPN/100mL)		
Bantug Pump Station	November 02, 2021 06:43 AM	1	<1.1	<1.1	PASSED
PNSDW Limits AO 2017-0010		<500	<1.1	<1.1	

Est. CFU/mL = Estimated Colony Forming Units per milliliter

MPN/100mL = Most Probable Number per 100 milliliters

- Note :**
- Test method used:
 - Pour Plate Method for the determination of Heterotrophic Plate Count
 - Multiple Tube Fermentation Technique for the determination of Total Coliform and Thermotolerant Coliform/E.coli
 - References:
 - Philippine National Standards for Drinking Water, 2017
 - Standard Methods for the Examination of Water and Wastewater, 22nd Edition, 2012, APHA, AWWA, WEF
 - Result of examination **specifically** relates to samples as received


Veronica A. Presentation, RMicro
Analyst, PAM No. 18-00303


Susana P. Quilaot, MD, FPSP
Head of the Laboratory, PRC No. 64242

Not Valid Without Dry Seal

WATER MICROBIOLOGY ANALYSIS REPORT

Client :	GUIMBA WATER DISTRICT	WMAR No :	21-07250
Owner/Manager :	ENGR. FELIXBERTO C. LEGARDA	Date Received :	11/02/2021
Address	DANZALAN ST., CORNER FAIGAL ST., GUIMBA, NUEVA ECIJA	Date Analyzed :	11/02/2021
		Date Completed :	11/05/2021

Physical Characteristics : **Sample is clear, with no foreign matter**

Sample Name	Date and Time of Sampling	Heterotrophic Plate Count (Est. CFU/mL)	Total Coliform	Thermotolerant Coliform / <i>E. coli</i>	Remarks
			(MPN/100mL)		
Nickville Subd.	November 02, 2021 06:30 AM	1	<1,1	<1,1	PASSED
PNSDW Limits AO 2017-0010		<500	<1,1	<1,1	


Est. CFU/mL = Estimated Colony Forming Units per milliliter

MPN/100mL = Most Probable Number per 100 milliliters

- Note :
- Test method used:
 - Pour Plate Method for the determination of Heterotrophic Plate Count
 - Multiple Tube Fermentation Technique for the determination of Total Coliform and Thermotolerant Coliform/E.coli
 - References:
 - Philippine National Standards for Drinking Water, 2017
 - Standard Methods for the Examination of Water and Wastewater, 22nd Edition, 2012, APHA, AWWA, WEF
 - Result of examination **specifically** relates to samples as received



Veronica A. Presentacion, RMicro
Analyst, PAM No. 18-00303



Susana P. Quiaoit, MD, FPSP
Head of the Laboratory, PRC No. 64242

Not Valid Without Dry Seal

WATER MICROBIOLOGY ANALYSIS REPORT

Client :	GUIMBA WATER DISTRICT	WMAR No :	21-0725N
Owner/Manager :	ENGR. FELIXBERTO C. LEGARDA	Date Received :	11/02/2021
Address	DANZALAN ST., CORNER FAIGAL ST., GUIMBA, NUEVA ECIJA	Date Analyzed :	11/02/2021
		Date Completed :	11/04/2021

Physical Characteristics : **Sample is clear, with no foreign matter**


Sample Name	Date and Time of Sampling	Heterotrophic Plate Count (Est. CFU/mL)	Total Coliform	Thermotolerant Coliform / <i>E. coli</i>	Remarks
			(MPN/100mL)		
San Roque Pump Station	November 02, 2021 06:35 AM	1	<1,1	<1.1	PASSED
PNSDW Limits AO 2017-0010		<500	<1,1	<1.1	

Est. CFU/mL = Estimated Colony Forming Units per milliliter

MPN/100mL = Most Probable Number per 100 milliliters

- Note :**
- Test method used:
 - Pour Plate Method for the determination of Heterotrophic Plate Count
 - Multiple Tube Fermentation Technique for the determination of Total Coliform and Thermotolerant Coliform/E.coli
 - References:
 - Philippine National Standards for Drinking Water, 2017
 - Standard Methods for the Examination of Water and Wastewater, 22nd Edition, 2012, APHA, AWWA, WEF
 - Result of examination **specifically** relates to samples as received


Veronica A. Presentacion, RMicro
Analyst, PAM No. 18-00303


Susana P. Quiaoit, MD, FPSP
Head of the Laboratory, PRC No. 64242

Not Valid Without Dry Seal



WATER MICROBIOLOGY ANALYSIS REPORT

Client :	GUIMBA WATER DISTRICT	WMAR No :	21-0725M
Owner/Manager :	ENGR. FELIXBERTO C. LEGARDA	Date Received :	11/02/2021
Address	DANZALAN ST., CORNER FAIGAL ST., GUIMBA, NUEVA ECIJA	Date Analyzed :	11/02/2021
		Date Completed :	11/04/2021

Physical Characteristics : Sample is clear, with no foreign matter

Sample Name	Date and Time of Sampling	Heterotrophic Plate Count (Est. CFU/mL)	Total Coliform	Thermotolerant Coliform / <i>E. coli</i>	Remarks
			(MPN/100mL)		
Bunol	November 02, 2021 06:15 AM	<1	<1,1	<1,1	PASSED
PNSDW Limits AO 2017-0010		<500	<1,1	<1,1	

Est. CFU/mL = Estimated Colony Forming Units per milliliter

MPN/100mL = Most Probable Number per 100 milliliters

- Note :
- Test method used:
 - Pour Plate Method for the determination of Heterotrophic Plate Count
 - Multiple Tube Fermentation Technique for the determination of Total Coliform and Thermotolerant Coliform/E.coli
 - References:
 - Philippine National Standards for Drinking Water, 2017
 - Standard Methods for the Examination of Water and Wastewater, 22nd Edition, 2012, APHA, AWWA, WEF
 - Result of examination **specifically** relates to samples as received

Veronica A. Presentacion, RMicro
Analyst, PAM No. 18-00303

Susana P. Quiaoit, MD, FPSP
Head of the Laboratory, PRC No. 64242

Not Valid Without Dry Seal

WATER MICROBIOLOGY ANALYSIS REPORT

Client :	GUIMBA WATER DISTRICT	WMAR No :	21-0725L
Owner/Manager :	ENGR. FELIXBERTO C. LEGARDA	Date Received :	11/02/2021
Address	DANZALAN ST., CORNER FAIGAL ST., GUIMBA, NUEVA ECIJA	Date Analyzed :	11/02/2021
		Date Completed :	11/04/2021

Physical Characteristics : **Sample is clear, with no foreign matter**


Sample Name	Date and Time of Sampling	Heterotrophic Plate Count (Est. CFU/mL)	Total Colliform	Thermotolerant Coliform / <i>E. coli</i>	Remarks
			(MPN/100mL)		
Triala	November 02, 2021 05:58 AM	<1	<1.1	<1.1	PASSED
PNSDW Limits AO 2017-0010		<500	<1.1	<1.1	

Est. CFU/mL = Estimated Colony Forming Units per milliliter

MPN/100mL = Most Probable Number per 100 milliliters

- Note :
- Test method used:
 - Pour Plate Method for the determination of Heterotrophic Plate Count
 - Multiple Tube Fermentation Technique for the determination of Total Coliform and Thermotolerant Coliform/E.coli
 - References:
 - Philippine National Standards for Drinking Water, 2017
 - Standard Methods for the Examination of Water and Wastewater, 22nd Edition, 2012, APHA, AWWA, WEF
 - Result of examination **specifically** relates to samples as received


Veronica A. Presentacion, RMicro
Analyst, PAM No. 18-00303


Susana P. Quilaoit, MD, FPSP
Head of the Laboratory, PRC No. 64242

Not Valid Without Dry Seal

WATER MICROBIOLOGY ANALYSIS REPORT

Client :	GUIMBA WATER DISTRICT	WMAR No :	21-0725K
Owner/Manager :	ENGR. FELIXBERTO C. LEGARDA	Date Received :	11/02/2021
Address	DANZALAN ST., CORNER FAIGAL ST., GUIMBA, NUEVA ECIJA	Date Analyzed :	11/02/2021
		Date Completed :	11/04/2021


Physical Characteristics : **Sample is clear, with no foreign matter**


Sample Name	Date and Time of Sampling	Heterotrophic Plate Count (Est. CFU/mL)	Total Coliform	Thermotolerant Coliform / <i>E. coli</i>	Remarks
			(MPN/100mL)		
Maturanoc Pump Station	November 02, 2021 05:51 AM	1	<1.1	<1.1	PASSED
PNSDW Limits AO 2017-0010		<500	<1.1	<1.1	

Est. CFU/mL = Estimated Colony Forming Units per milliliter

MPN/100mL = Most Probable Number per 100 milliliters

- Note :
- Test method used:
 - Pour Plate Method for the determination of Heterotrophic Plate Count
 - Multiple Tube Fermentation Technique for the determination of Total Coliform and Thermotolerant Coliform/E.coli
 - References:
 - Philippine National Standards for Drinking Water, 2017
 - Standard Methods for the Examination of Water and Wastewater, 22nd Edition, 2012, APHA, AWWA, WEF
 - Result of examination **specifically** relates to samples as received


Veronica A. Presentation, RMicro
Analyst, PAM No. 18-00303


Susana P. Quilait, MD, FPSP
Head of the Laboratory, PRC No. 64242

Not Valid Without Dry Seal

WATER MICROBIOLOGY ANALYSIS REPORT

Client :	GUIMBA WATER DISTRICT	WMAR No :	21-0725J
Owner/Manager :	ENGR. FELIXBERTO C. LEGARDA	Date Received :	11/02/2021
Address	DANZALAN ST., CORNER FAIGAL ST., GUIMBA, NUEVA ECIJA	Date Analyzed :	11/02/2021
		Date Completed :	11/04/2021

Physical Characteristics : **Sample is clear, with no foreign matter**


Sample Name	Date and Time of Sampling	Heterotrophic Plate Count (Est. CFU/mL)	Total Coliform	Thermotolerant Coliform / <i>E. coli</i>	Remarks
			(MPN/100mL)		
Lamorito	November 02, 2021 05:31 AM	3	<1.1	<1.1	PASSED
PNSDW Limits AO 2017-0010		<500	<1.1	<1.1	

Est. CFU/mL = Estimated Colony Forming Units per milliliter

MPN/100mL = Most Probable Number per 100 milliliters

- Note :
- Test method used:
 - Pour Plate Method for the determination of Heterotrophic Plate Count
 - Multiple Tube Fermentation Technique for the determination of Total Coliform and Thermotolerant Coliform/E.coli
 - References:
 - Philippine National Standards for Drinking Water, 2017
 - Standard Methods for the Examination of Water and Wastewater, 22nd Edition, 2012, APHA, AWWA, WEF
 - Result of examination **specifically** relates to samples as received


Veronica A. Presentation, RMicro
Analyst, PAM No. 18-00303


Susana P. Quiaoit, MD, FPSP
Head of the Laboratory, PRC No. 64242

Not Valid Without Dry Seal

WATER MICROBIOLOGY ANALYSIS REPORT

Client :	GUIMBA WATER DISTRICT	WMAR No :	21-07251
Owner/Manager :	ENGR. FELIXBERTO C. LEGARDA	Date Received :	11/02/2021
Address	DANZALAN ST., CORNER FAIGAL ST., GUIMBA, NUEVA ECIJA	Date Analyzed :	11/02/2021
		Date Completed :	11/04/2021

Physical Characteristics : **Sample is clear, with no foreign matter**

Sample Name	Date and Time of Sampling	Heterotrophic Plate Count (Est. CFU/mL)	Total Coliform	Thermotolerant Coliform / <i>E. coli</i>	Remarks
			(MPN/100mL)		
Yuzon	November 02, 2021 05:14 AM	<1	<1.1	<1.1	PASSED
PNSDW Limits AO 2017-0010		<500	<1.1	<1.1	


Est. CFU/mL = Estimated Colony Forming Units per milliliter

MPN/100mL = Most Probable Number per 100 milliliters

- Note :
- Test method used:
 - Pour Plate Method for the determination of Heterotrophic Plate Count
 - Multiple Tube Fermentation Technique for the determination of Total Coliform and Thermotolerant Coliform/E.coli
 - References:
 - Philippine National Standards for Drinking Water, 2017
 - Standard Methods for the Examination of Water and Wastewater, 22nd Edition, 2012, APHA, AWWA, WEF
 - Result of examination **specifically** relates to samples as received



Veronica A. Presentacion, RMicro
Analyst, PAM No. 18-00303



Susana P. Quiaoit, MD, FPSP
Head of the Laboratory, PRC No. 64242

Not Valid Without Dry Seal

WATER MICROBIOLOGY ANALYSIS REPORT

Client :	GUIMBA WATER DISTRICT	WMAR No :	21-0725H
Owner/Manager :	ENGR. FELIXBERTO C. LEGARDA	Date Received :	11/02/2021
Address	DANZALAN ST., CORNER FAIGAL ST., GUIMBA, NUEVA ECIJA	Date Analyzed :	11/02/2021
		Date Completed :	11/04/2021


Physical Characteristics : **Sample is clear, with no foreign matter**


Sample Name	Date and Time of Sampling	Heterotrophic Plate Count (Est. CFU/mL)	Total Coliform	Thermotolerant Coliform / <i>E. coli</i>	Remarks
			(MPN/100mL)		
San Rafael Pump Station	November 02, 2021 04:59 AM	16	<1.1	<1.1	PASSED
PNSDW Limits AO 2017-0010		<500	<1.1	<1.1	

Est. CFU/mL = Estimated Colony Forming Units per milliliter

MPN/100mL = Most Probable Number per 100 milliliters

- Note :
- Test method used:
 - Pour Plate Method for the determination of Heterotrophic Plate Count
 - Multiple Tube Fermentation Technique for the determination of Total Coliform and Thermotolerant Coliform/E.coli
 - References:
 - Philippine National Standards for Drinking Water, 2017
 - Standard Methods for the Examination of Water and Wastewater, 22nd Edition, 2012, APHA, AWWA, WEF
 - Result of examination **specifically** relates to samples as received


Veronica A. Presentation, RMicro
Analyst, PAM No. 18-00303


Susana P. Quilait, MD, FPSP
Head of the Laboratory, PRC No. 64242

Not Valid Without Dry Seal

WATER MICROBIOLOGY ANALYSIS REPORT

Client :	GUIMBA WATER DISTRICT	WMAR No :	21-0725G
Owner/Manager :	ENGR. FELIXBERTO C. LEGARDA	Date Received :	11/02/2021
Address	DANZALAN ST., CORNER FAIGAL ST., GUIMBA, NUEVA ECIJA	Date Analyzed :	11/02/2021
		Date Completed :	11/04/2021

Physical Characteristics : **Sample is clear, with no foreign matter**


Sample Name	Date and Time of Sampling	Heterotrophic Plate Count (Est. CFU/mL)	Total Coliform	Thermotolerant Coliform / <i>E. coli</i>	Remarks
			(MPN/100mL)		
Lennece	November 02, 2021 04:50 AM	<1	<1,1	<1,1	PASSED
PNSDW Limits AO 2017-0010		<500	<1,1	<1,1	

Est. CFU/mL = Estimated Colony Forming Units per milliliter

MPN/100mL = Most Probable Number per 100 milliliters

- Note :**
- Test method used:
 - Pour Plate Method for the determination of Heterotrophic Plate Count
 - Multiple Tube Fermentation Technique for the determination of Total Coliform and Thermotolerant Coliform/E.coli
 - References:
 - Philippine National Standards for Drinking Water, 2017
 - Standard Methods for the Examination of Water and Wastewater, 22nd Edition, 2012, APHA, AWWA, WEF
 - Result of examination **specifically** relates to samples as received


Veronica A. Presentation, RMicro
Analyst, PAM No. 18-00303


Susana P. Quiaoit, MD, FPSP
Head of the Laboratory, PRC No. 64242

Not Valid Without Dry Seal

WATER MICROBIOLOGY ANALYSIS REPORT

Client :	GUIMBA WATER DISTRICT	WMAR No :	21-0725F
Owner/Manager :	ENGR. FELIXBERTO C. LEGARDA	Date Received :	11/02/2021
Address	DANZALAN ST., CORNER FAIGAL ST., GUIMBA, NUEVA ECIJA	Date Analyzed :	11/02/2021
		Date Completed :	11/04/2021

Physical Characteristics : **Sample is clear, with no foreign matter**


Sample Name	Date and Time of Sampling	Heterotrophic Plate Count (Est. CFU/mL)	Total Coliform	Thermotolerant Coliform / <i>E. coli</i>	Remarks
			(MPN/100mL)		
Narvacan 1 Pump Station	November 02, 2021 04:41 AM	46	<1.1	<1.1	PASSED
PNSDW Limits AO 2017-0010		<500	<1.1	<1.1	

Est. CFU/mL = Estimated Colony Forming Units per milliliter

MPN/100mL = Most Probable Number per 100 milliliters

- Note :
- Test method used:
 - Pour Plate Method for the determination of Heterotrophic Plate Count
 - Multiple Tube Fermentation Technique for the determination of Total Coliform and Thermotolerant Coliform/E.coli
 - References:
 - Philippine National Standards for Drinking Water, 2017
 - Standard Methods for the Examination of Water and Wastewater, 22nd Edition, 2012, APHA, AWWA, WEF
 - Result of examination **specifically** relates to samples as received


Veronica A. Presentacion, RMicro
Analyst, PAM No. 18-00303


Susana P. Quiaoit, MD, FPSP
Head of the Laboratory, PRC No. 64242

Not Valid Without Dry Seal

WATER MICROBIOLOGY ANALYSIS REPORT

Client :	GUIMBA WATER DISTRICT	WMAR No :	21-0725E
Owner/Manager :	ENGR. FELIXBERTO C. LEGARDA	Date Received :	11/02/2021
Address	DANZALAN ST., CORNER FAIGAL ST., GUIMBA, NUEVA ECIJA	Date Analyzed :	11/02/2021
		Date Completed :	11/04/2021

Physical Characteristics : **Sample is clear, with no foreign matter**


Sample Name	Date and Time of Sampling	Heterotrophic Plate Count (Est. CFU/mL)	Total Coliform	Thermotolerant Coliform / <i>E. coli</i>	Remarks
			(MPN/100mL)		
Casongsong	November 02, 2021 04:32 AM	<1	<1.1	<1.1	PASSED
PNSDW Limits AO 2017-0010		<500	<1.1	<1.1	

Est. CFU/mL = Estimated Colony Forming Units per milliliter

MPN/100mL = Most Probable Number per 100 milliliters

- Note :**
- Test method used:
 - Pour Plate Method for the determination of Heterotrophic Plate Count
 - Multiple Tube Fermentation Technique for the determination of Total Coliform and Thermotolerant Coliform/E.coli
 - References:
 - Philippine National Standards for Drinking Water, 2017
 - Standard Methods for the Examination of Water and Wastewater, 22nd Edition, 2012, APHA, AWWA, WEF
 - Result of examination **specifically** relates to samples as received


Veronica A. Presentacion, RMicro
Analyst, PAM No. 18-00303


Susana P. Quiaoit, MD, FPSP
Head of the Laboratory, PRC No. 64242

Not Valid Without Dry Seal

WATER MICROBIOLOGY ANALYSIS REPORT

Client :	GUIMBA WATER DISTRICT	WMAR No :	21-0725D
Owner/Manager :	ENGR. FELIXBERTO C. LEGARDA	Date Received :	11/02/2021
Address	DANZALAN ST., CORNER FAIGAL ST., GUIMBA, NUEVA ECIJA	Date Analyzed :	11/02/2021
		Date Completed :	11/04/2021


Physical Characteristics : **Sample is clear, with no foreign matter**


Sample Name	Date and Time of Sampling	Heterotrophic Plate Count (Est. CFU/mL)	Total Coliform	Thermotolerant Coliform / <i>E. coli</i>	Remarks
			(MPN/100mL)		
Bacayao Pump Station	November 02, 2021 04:24 AM	<1	<1.1	<1.1	PASSED
PNSDW Limits AO 2017-0010		<500	<1.1	<1.1	

Est. CFU/mL = Estimated Colony Forming Units per milliliter

MPN/100mL = Most Probable Number per 100 milliliters

- Note :
- Test method used:
 - Pour Plate Method for the determination of Heterotrophic Plate Count
 - Multiple Tube Fermentation Technique for the determination of Total Coliform and Thermotolerant Coliform/E.coli
 - References:
 - Philippine National Standards for Drinking Water, 2017
 - Standard Methods for the Examination of Water and Wastewater, 22nd Edition, 2012, APHA, AWWA, WEF
 - Result of examination **specifically** relates to samples as received


Veronica A. Presentation, RMicro
Analyst, PAM No. 18-00303


Susana P. Quiaoit, MD, FPSP
Head of the Laboratory, PRC No. 64242

Not Valid Without Dry Seal

WATER MICROBIOLOGY ANALYSIS REPORT

Client :	GUIMBA WATER DISTRICT	WMAR No :	21-0725C
Owner/Manager :	ENGR. FELIXBERTO C. LEGARDA	Date Received :	11/02/2021
Address	DANZALAN ST., CORNER FAIGAL ST., GUIMBA, NUEVA ECIJA	Date Analyzed :	11/02/2021
		Date Completed :	11/04/2021

Physical Characteristics : **Sample is clear, with no foreign matter**


Sample Name	Date and Time of Sampling	Heterotrophic Plate Count (Est. CFU/mL)	Total Coliform	Thermotolerant Coliform / <i>E. coli</i>	Remarks
			(MPN/100mL)		
Cavite	November 02, 2021 04:14 AM	370	<1,1	<1,1	PASSED
PNSDW Limits AO 2017-0010		<500	<1,1	<1,1	

Est. CFU/mL = Estimated Colony Forming Units per milliliter

MPN/100mL = Most Probable Number per 100 milliliters

- Note :
- Test method used:
 - Pour Plate Method for the determination of Heterotrophic Plate Count
 - Multiple Tube Fermentation Technique for the determination of Total Coliform and Thermotolerant Coliform/*E. coli*
 - References:
 - Philippine National Standards for Drinking Water, 2017
 - Standard Methods for the Examination of Water and Wastewater, 22nd Edition, 2012, APHA, AWWA, WEF
 - Result of examination **specifically** relates to samples as received


Veronica A. Presentacion, RMicro
Analyst, PAM No. 18-00303


Susana P. Quiaoit, MD, FPSP
Head of the Laboratory, PRC No. 64242

Not Valid Without Dry Seal

WATER MICROBIOLOGY ANALYSIS REPORT

Client :	GUIMBA WATER DISTRICT	WMAR No :	21-0725B
Owner/Manager :	ENGR. FELIXBERTO C. LEGARDA	Date Received :	11/02/2021
Address	DANZALAN ST., CORNER FAIGAL ST., GUIMBA, NUEVA ECIJA	Date Analyzed :	11/02/2021
		Date Completed :	11/04/2021


Physical Characteristics : **Sample is clear, with no foreign matter**


Sample Name	Date and Time of Sampling	Heterotrophic Plate Count (Est. CFU/mL)	Total Coliform	Thermotolerant Coliform / <i>E. coli</i>	Remarks
			(MPN/100mL)		
Sta. Lucia	November 02, 2021 04:07 AM	450	<1.1	<1.1	PASSED
PNSDW Limits AO 2017-0010		<500	<1.1	<1.1	

Est. CFU/mL = Estimated Colony Forming Units per milliliter

MPN/100mL = Most Probable Number per 100 milliliters

- Note :
- Test method used:
 - Pour Plate Method for the determination of Heterotrophic Plate Count
 - Multiple Tube Fermentation Technique for the determination of Total Coliform and Thermotolerant Coliform/E.coli
 - References:
 - Philippine National Standards for Drinking Water, 2017
 - Standard Methods for the Examination of Water and Wastewater, 22nd Edition, 2012, APHA, AWWA, WEF
 - Result of examination **specifically** relates to samples as received


Veronica A. Presentacion, RMicro
Analyst, PAM No. 18-00303


Susana P. Quiaoit, MD, FPSP
Head of the Laboratory, PRC No. 64242

Not Valid Without Dry Seal

WATER MICROBIOLOGY ANALYSIS REPORT

Client :	GUIMBA WATER DISTRICT	WMAR No :	21-0725A
Owner/Manager :	ENGR. FELIXBERTO C. LEGARDA	Date Received :	11/02/2021
Address	DANZALAN ST., CORNER FAIGAL ST., GUIMBA, NUEVA ECIJA	Date Analyzed :	11/02/2021
		Date Completed :	11/04/2021


Physical Characteristics : **Sample is clear, with no foreign matter**

Sample Name	Date and Time of Sampling	Heterotrophic Plate Count (Est. CFU/mL)	Total Coliform	Thermotolerant Coliform / <i>E. coli</i>	Remarks
			(MPN/100mL)		
Sta. Veronica Pump Station	November 02, 2021 04:01 AM	400	<1.1	<1.1	PASSED
PNSDW Limits AO 2017-0010		<500	<1.1	<1.1	


Est. CFU/mL = Estimated Colony Forming Units per milliliter

MPN/100mL = Most Probable Number per 100 milliliters

- Note :
- Test method used:
 - Pour Plate Method for the determination of Heterotrophic Plate Count
 - Multiple Tube Fermentation Technique for the determination of Total Coliform and Thermotolerant Coliform/E.coli
 - References:
 - Philippine National Standards for Drinking Water, 2017
 - Standard Methods for the Examination of Water and Wastewater, 22nd Edition, 2012, APHA, AWWA, WEF
 - Result of examination **specifically** relates to samples as received



Veronica A. Presentacion, RMicro
Analyst, PAM No. 18-00303



Susana P. Quiaoit, MD, FPSP
Head of the Laboratory, PRC No. 64242